

Network Performance Standards for Revised Baselines Rule 26

This Rule provides general terms and conditions for the Company's Network Performance Standards pertinent to its revised baselines (called Performance Standards or PS) which are applicable in the Company's Wyoming service territory.

Network Performance Standards:

A. Performance Standard 1: System Average Interruption Duration Index (SAIDI)

The Company will, by 3/31/2008, have delivered a Fiscal Year SAIDI (without Major Events) of 150 minutes.

SAIDI is calculated by dividing the total Customer Minutes Lost for the state of Wyoming by its Fiscal Frozen Customer Count. The Customer Minutes Lost are recorded and summarized in the Company's Outage Reporting System. The Fiscal Frozen Customer Count is calculated and reported in the Company's Outage Reporting System.

B. Performance Standard 2: System Average Interruption Frequency Index (SAIFI)

The Company will, by 3/31/2008, have delivered a Fiscal Year SAIFI (without Major Events) of 1.59 events.

SAIFI is calculated by dividing the total Sustained Customer Interruptions for the state of Wyoming by its Fiscal Frozen Customer Count. The Sustained Customer Interruptions are recorded and summarized in the Company's Outage Reporting System. The Fiscal Frozen Customer Count is calculated and reported in the Company's Outage Reporting System.

C. General Exceptions:

The following constitute exceptions to the requirements in A and B above:

1. Major events, such as storms, as currently defined by the Institute of Electrical and Electronics Engineers, Inc. (IEEE), in Standard P1366-2003.

(continued)

Issued by
Jeffrey K. Larsen, Vice President, Regulation

Issued: April 18, 2008

Effective: With service rendered
on and after May 1, 2008

Network Performance Standards for Revised Baselines Rule 26

C. General Exceptions: *(continued)*

2. Causes related to force majeure, as specified in Rule 4, Section II, B, Continuity of Electric Service and Interruption (Force Majeure).

This rule is amended and filed in compliance with the Public Service Commission of Wyoming approved revised Network Performance Baselines for System Average Interruption Duration Index (SAIDI) and System Average Interruption Frequency Index (SAIFI) as approved in Docket No. 20000-EA-03-203 (Record No. 8473) and extension of the Company's Service Standard Program as approved in Docket-EA-20000-ET-04-216 (Record No. 9531).

Issued by
Jeffrey K. Larsen, Vice President, Regulation

Issued: April 18, 2008

Effective: With service rendered
on and after May 1, 2008