

Rocky Mountain Power
Exhibit RMP____(FRS-1)
Docket No. 20000-____-ER-11
Witness:

BEFORE THE WYOMING PUBLIC SERVICE
COMMISSION

ROCKY MOUNTAIN POWER

Exhibit Accompanying Direct Testimony of F. Robert Stewart

The Summary of Rule Changes

December 2011

Brief Summary of Rule Changes
(rule: section in parenthesis)

Rule 12, Line Extension

- A. Incorporate the Cost Allocation Policy included in the 2010 GRC settlement in Rule 12, Line Extension
 - 1. Add definition of Direct Assigned Facilities. (R12: Section I.C).
 - 2. Add definition of Network Upgrade (R12: Section I.J).

- B. Other changes to Rule 12, Line Extension
 - 1. Clarify that residential transformer upgrade criteria using the term “capacity” means rated capacity not overload capacity (R12: Section II.E).
 - 2. Restore the 50% payment language for 1,000kW and greater customers (R12: Section III.B.2).
 - 3. Change the years of non-use before no longer reserving capacity from three (3) years to five (5) years (R12: Section III.D).
 - 4. Correct typos (R12: Section II.B, II.C.1).

Rule 4, Type and Use of Service

- C. State that dispersed loads of extractive industries may be served from a single point of delivery without having to be located on a single premise (R4: Section I.A).

Rule 6, Company’s Installation

- D. Update the list of standard secondary service voltages (R6: Section II.B.1, II.B.2).