

Rocky Mountain Power
Exhibit RMP___(DTG-2)
Docket No. 20000-___-ER-11
Witness: Darrell T. Gerrard

BEFORE THE WYOMING PUBLIC SERVICE
COMMISSION

ROCKY MOUNTAIN POWER

Exhibit Accompanying Direct Testimony of Darrell T. Gerrard

WECC Rated Path Utilization 2010

December 2011

Exhibit RMP___ (DTG-2)

Chart #1- WECC Rated Path Flow Utilization

WECC Rated Path	Path Flow			
	U95	U75		
TOT 4A/4B*	1.40%	45.40%		
Bridger West	5.00%	66.30%		
Path C**	1%	2.20%		
Yellowtail South	Not a WECC monitored path***			
West of Rock Springs	Not a WECC monitored path***			
Monument West	Not a WECC monitored path***			
Evanston West	Not a WECC monitored path***			
West of Naughton	Not a WECC monitored path***			

Chart #2-WECC Rated Path Shedule Utilization

WECC Rated Path	Path Schedule			
	U95	U75		
TOT 4A/4B*	20.10%	60.30%		
Bridger West	20.50%	82.40%		
Path C**	2.10%	6.20%		
Yellowtail South	Not a WECC monitored path***			
West of Rock Springs	Not a WECC monitored path***			
Monument West	Not a WECC monitored path***			
Evanston West	Not a WECC monitored path***			
West of Naughton	Not a WECC monitored path***			

*Data derived from TOT4A/B WECC Approved Simultaneous Operating Limits Nomogram

** Bi-Directional Rated Path after Populus Terminal Project. Capacity Held for Contingency Reserves Not Scheduled Hourly

***Not scheduled hourly. Limits cannot be exceeded due to constraints on WECC Rated Paths

Chart #3 Total Transmission Capacity (TTC) and Available Transmission Capacity (ATC)

WECC Rated Path	TTC MW	ATC MW		
	TOT 4A/4B*	8204A 6804B		
Bridger West	2200	0		
Path C**	1600SB 1250NB	0SB 315NB		
Yellowtail South	Not a WECC monitored path***			
West of Rock Springs	Not a WECC monitored path***			
Monument West	Not a WECC monitored path***			
Evanston West	Not a WECC monitored path***			
West of Naughton	Not a WECC monitored path***			