

Exhibit 19: Overview of PacifiCorp's Environmental Control Plan

Unit	Year Installed	Regulatory Depreciation Life (non-OR)	Accredited Net MW Rating (100% Share)	NOx Emission Controls					SO ₂ Emission Controls		Particulate Controls			Mercury (Hg) Control	CCB Compliance	Potential to Operate on Full Load Natural Gas	PacifiCorp Ownership
				Neural Network System	Low Nox Burners	Overfire Air	Selective Non-Catalytic Reduction	Selective Catalytic Reduction	Dry Scrubber	Wet Scrubber	Electrostatic Precipitator	Wet Scrubber	Baghouse	Activated Carbon Injection	(Dates shown are initial compliance projects in-service) Pond closure, wet-to-dry conversion, new facilities		
Carbon 1	1954	2020	67	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	In Service Cold Side	-	Not Planned	2014 - Coal Oxidizer	2017	Under Review	100.00%
Carbon 2	1957	2020	105	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	In Service Cold Side	-	Not Planned	2014 - Coal Oxidizer	2017	Under Review	100.00%
Cholla 4	1981	2042	395	Not Planned	In Service	In Service	Not Planned	Not Planned	N/A	In Service	N/A	-	In Service	2014 - Coal Oxidizer	2017	Not Planned	100.00%
Colstrip 3	1984	2046	740	Not Planned	In Service	In Service	Not Planned	Not Planned	N/A	In Service	N/A	In Service	N/A	In Service	2017	Not Planned	100.00%
Colstrip 4	1986	2046	740	Not Planned	In Service	In Service	Not Planned	Not Planned	N/A	In Service	N/A	In Service	N/A	In Service	2017	Not Planned	100.00%
Craig 1	1980	2034	428	Not Planned	In Service	In Service	2017	Not Planned	N/A	In Service	N/A	-	In Service	2014 - Coal Oxidizer	2017	Not Planned	19.28%
Craig 2	1979	2034	428	Not Planned	In Service	In Service	Not Planned	2016	N/A	In Service	N/A	-	In Service	2014 - Coal Oxidizer	2017	Not Planned	19.28%
Dave Johnston 1	1958	2027	106	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Under Review	100.00%
Dave Johnston 2	1960	2027	106	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	Not Planned	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Under Review	100.00%
Dave Johnston 3	1964	2027	220	Not Planned	In Service	In Service	Not Planned	Not Planned	In Service	N/A	N/A	-	In Service	2014 - Sorb Inj + Oxidizer	2017	Not Planned	100.00%
Dave Johnston 4	1972	2027	330	Not Planned	In Service	In Service	Not Planned	Not Planned	2012	N/A	In Service Cold Side	-	2012	2014 - Sorb Inj + Oxidizer	2017	Not Planned	100.00%
Hayden 1	1965	2030	184	Not Planned	In Service	In Service	Not Planned	2015	In Service	N/A	N/A	-	In Service	2014 - Sorbent Injection	2017	Not Planned	24.46%
Hayden 2	1976	2030	262	Not Planned	In Service	In Service	Not Planned	2016	In Service	N/A	N/A	-	In Service	2014 - Sorbent Injection	2017	Not Planned	12.60%
Hunter 1	1978	2042	430	Not Planned	2014	2014	Not Planned	2026 ¹	N/A	In Service 2014 -Upgrade	In Service Cold Side	-	2014	Not Planned	2017	Not Planned	93.75%
Hunter 2	1980	2042	430	Not Planned	In Service	In Service	Not Planned	2023 ¹	N/A	In Service	N/A	-	In Service	Not Planned	2017	Not Planned	60.31%
Hunter 3	1983	2042	460	Not Planned	In Service	In Service	Not Planned	2024 ¹	N/A	In Service	N/A	-	In Service	Not Planned	2017	Not Planned	100.00%
Huntington 1	1977	2036	445	Not Planned	In Service	In Service	Not Planned	2023 ¹	N/A	In Service	N/A	-	In Service	Not Planned	2017	Not Planned	100.00%
Huntington 2	1974	2036	450	Not Planned	In Service	In Service	Not Planned	2026 ¹	N/A	In Service	N/A	-	In Service	Not Planned	2017	Not Planned	100.00%
Jim Bridger 1	1974	2037	530	Not Planned	In Service	In Service	Not Planned	2022	N/A	In Service	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	66.67%
Jim Bridger 2	1975	2037	527	Not Planned	In Service	In Service	Not Planned	2021	N/A	In Service	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	66.67%
Jim Bridger 3	1976	2037	530	Not Planned	In Service	In Service	Not Planned	2015	N/A	In Service	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	66.67%
Jim Bridger 4	1979	2037	530	Not Planned	In Service	In Service	Not Planned	2016	N/A	In Service	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	66.67%
Naughton 1	1963	2029	160	Not Planned	2012	2012	Not Planned	Not Planned	N/A	2012	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	100.00%
Naughton 2	1968	2029	210	Not Planned	2011	2011	Not Planned	Not Planned	N/A	2011	In Service Cold Side	-	Not Planned	2014 - Sorb Inj + Oxidizer	2017	Not Planned	100.00%
Naughton 3	1971	2029	330	Not Planned	In Service	In Service	Not Planned	2014	N/A	In Service 2014-Upgrade	In Service Cold Side	-	2014	2014 - Sorb Inj + Oxidizer	2017	Not Planned	100.00%
Wyodak	1978	2039	335	Not Planned	In Service	In Service	Not Planned	2026 ¹	In Service	N/A	N/A	-	In Service	2014 - Sorb Inj + Oxidizer	2017	Not Planned	80.00%

1. PacifiCorp has included these SCRs in its economic analyses to add conservatism to the results presented. SCRs are required at Jim Bridger Units 1-4 and Naughton Unit 3; however, no company commitments or agency actions have been taken that require installation of the other SCRs listed.