

## Incentives for motors

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement	Customer Incentive
<b>Electronically Commutated Motor</b>	≤1 horsepower	Refrigeration application	--	\$0.50/watt
		HVAC application	--	\$50/horsepower
<b>Variable-Frequency Drives</b> (HVAC fans and pumps)	≤100 horsepower	HVAC fans and pumps	See note 2	\$65/horsepower
<b>Green Motor Rewinds</b>	≥15 and ≤ 5,000 hp	--	Must meet GMPG Standards	\$1/horsepower (See note 3)

### Notes for other motor incentives:

1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for an incentive.
2. Throttling or bypass devices, such as inlet vanes, bypass dampers, three-way valves, or throttling valves must be removed or permanently disabled to qualify for HVAC fan or pump VFD incentives. This program uses the International Energy Conservation Code (IECC) as the baseline for new construction and major renovation energy efficiency projects. VFDs required by or used to comply with the applicable version of the IECC are not eligible for incentives. Savings will only be realized for installations where a variable load is present.
3. For Green Motor Rewinds, the participating electric motor service center is paid \$2/horsepower for eligible Green Motor Rewinds. A minimum of \$1/horsepower is paid by the service center to the customer as a credit on the motor rewind invoice. The balance is retained by the service center. Green Motor Rewind motors that are installed or placed in inventory may qualify for an incentive.
4. **Incentives are not available for National Electrical Manufacturers Association (NEMA) premium efficiency motors purchased on or after December 19, 2010.**

ECM = Electronically Commutated Motor  
 GMPG = Green Motors Practices Group  
 HVAC = Heating, Ventilating and Air Conditioning  
 IECC = International Energy Conservation Code  
 VFD = Variable Frequency Drive



Let's turn the answers on.