

Rocky Mountain Power
Docket No. 17-035-39
Witness: Timothy J. Hemstreet

BEFORE THE PUBLIC SERVICE COMMISSION
OF THE STATE OF UTAH

ROCKY MOUNTAIN POWER

Direct Testimony of Timothy J. Hemstreet

June 2017

1 **Q. Please state your name, business address and present position with PacifiCorp.**

2 A. My name is Timothy J. Hemstreet. My business address is 825 NE Multnomah Street,
3 Suite 1500, Portland, Oregon 97232. My present position is Director of Renewable
4 Energy Development. I am testifying on behalf of Rocky Mountain Power
5 (“Company”), a division of PacifiCorp.

6 **QUALIFICATIONS**

7 **Q. Briefly describe your education and business experience.**

8 A. I hold a Bachelor of Science degree in Civil Engineering from the University of Notre
9 Dame in Indiana and a Master of Science degree in Civil Engineering from the
10 University of Texas at Austin. I am also a Registered Professional Engineer in the state
11 of Oregon. Before joining the Company in 2004, I held positions in engineering
12 consulting and environmental compliance. Since joining the Company, I have held
13 positions in environmental policy, engineering, project management, and hydroelectric
14 project licensing and program management. In 2016, I assumed the role of Director of
15 Renewable Energy Development, in which I oversee the development of renewable
16 energy resources.

17 **PURPOSE OF TESTIMONY**

18 **Q. What is the purpose of your testimony?**

19 A. In support of the Company’s application for approval of wind repowering and
20 associated ratemaking treatment, my testimony provides technical information
21 regarding the Company’s proposal to upgrade, or “repower,” most of its wind fleet.
22 Specifically, my testimony addresses:

- 23
 - The scope of the project;

- 24 • The benefits of repowering resulting from the qualification for federal
- 25 production tax credits (“PTCs”);
- 26 • The increased energy benefits following repowering;
- 27 • The reduced ongoing operating costs following repowering;
- 28 • System transmission reliability related to the project;
- 29 • The extension of wind facility asset lives after repowering;
- 30 • Project contract status and construction schedule; and
- 31 • The disposition of removed equipment.

32 OVERVIEW OF WIND REPOWERING AND PROJECT SCOPE

33 **Q. Please briefly describe what repowering a wind facility entails.**

34 A. Repowering broadly describes the upgrade of an existing, operating wind facility with
35 new wind-turbine-generator (“WTG”) equipment that can increase a facility’s
36 generating capacity and the amount of electrical generation produced from the facility.
37 Exhibit RMP___(TJH-1) is a depiction of a wind turbine and its various components.
38 The Company proposes to repower its wind facilities by replacing the nacelle, hub and
39 rotor of the WTG.

40 **Q. Which facilities does the Company propose to repower?**

41 A. The Company is planning to upgrade all of its wind facilities in Wyoming except the
42 Foote Creek facility (Glenrock I, Glenrock III, Rolling Hills, Seven Mile Hill I, Seven
43 Mile Hill II, High Plains, McFadden Ridge, and Dunlap); the Leaning Juniper facility
44 in Oregon; and the Marengo I, Marengo II, and Goodnoe Hills facilities in Washington.

45 **Q. Please explain why repowering is feasible for these wind facilities.**

46 A. The wind facilities the Company proposes to repower began commercial operations

47 between 2006 and 2010. Because they were recently developed, they can be
48 economically repowered, or upgraded, with new technology that will improve their
49 efficiency and increase their generation output, while retaining the existing towers,
50 foundations, and energy collection systems. The existing foundations and towers,
51 although more than 10 years old in some instances, are adequately designed to
52 accommodate larger, more modern WTG equipment and have a sufficient remaining
53 useful life to economically justify the associated investment.

54 In contrast, at facility sites developed more than about 15 years ago, the WTG
55 equipment typically has a low generating capacity (*i.e.*, sub-1,000 kilowatt) and the
56 towers and foundations supporting the nacelle and rotor do not have the height or
57 design strength to accommodate the installation of modern, larger nacelles and rotors
58 capable of generating a much greater amount of electricity per WTG. With these older
59 facilities, repowering usually involves the entire removal of the old wind turbine
60 equipment and the redevelopment of the site with modern wind turbines that have much
61 greater generating capacity. This can result in significantly fewer wind turbines needed
62 to produce an equivalent generating capacity, while also increasing energy output.

63 The ability to repower facilities while reusing the existing infrastructure of the
64 towers, foundations, and energy collection system is highly beneficial because the
65 energy and PTC benefits can be realized with a lower capital investment, as compared
66 to the more comprehensive site redevelopment required for older facilities.

67 **Q. Did the Company's 2017 Integrated Resource Plan ("2017 IRP") evaluate**
68 **repowering all of the resources covered by the application?**

69 A. Yes, except for Goodnoe Hills. When the 2017 IRP was developed, the Company had

70 not assessed repowering Goodnoe Hills. Since that time, however, the Company has
71 evaluated the facility and believes Goodnoe Hills can be economically repowered
72 similar to the facilities evaluated in the 2017 IRP.

73 **Q. Why did the Company exclude Foote Creek in Wyoming from the proposed wind**
74 **repowering project at this time?**

75 A. As noted in the 2017 IRP action plan item 1a, the Company is still evaluating the
76 potential of repowering Foote Creek. Repowering this older facility would involve
77 more comprehensive site redevelopment, as described above, which is different in
78 scope than the repowering projects proposed here. If the Company determines that
79 repowering Foote Creek is economic for customers, it will pursue the appropriate
80 regulatory process for doing so.

81 **Q. How many megawatts (“MW”) of installed wind capacity is the Company**
82 **proposing to repower?**

83 A. The Company is proposing to repower 12 of its 13 wind facilities, representing
84 999.1 MW of installed wind capacity. Broken down by state, this consists of eight
85 facilities in Wyoming comprising 594 MW, one facility in Oregon of 100.5 MW, and
86 three facilities in Washington comprising 304.6 MW. Detailed information about the
87 wind facilities the Company proposes to repower is included in
88 Exhibit RMP____(TJH-2).

89 **BENEFITS OF REPOWERING INCLUDING REQUALIFICATION FOR**
90 **PRODUCTION TAX CREDITS**

91 **Q. What benefits will customers realize from wind repowering?**

92 A. Repowering the proposed wind facilities will requalify them for PTCs, and the benefits

93 will be fully passed on to the Company's customers with the ratemaking treatment
94 discussed by Company witness Mr. Jeffrey K. Larsen. Additionally, repowering will
95 increase the amount of zero-fuel-cost energy produced from the repowered turbines
96 which will range from 11 to 35 percent, depending on the facility.¹ It will reduce
97 ongoing operating costs as a result of replacing older WTG equipment subject to more
98 failure and maintenance issues than newer equipment. Finally, repowering the wind
99 facilities with new WTG equipment will extend the useful lives of the facilities by at
100 least 10 years, creating substantial energy benefits for customers in the future when
101 these wind facilities would otherwise have been retired from service.

102 **Q. How are the repowered wind facilities able to requalify for PTCs?**

103 A. On December 18, 2015, Congress enacted changes to the federal Internal Revenue
104 Code that extended the full value of the PTC for wind energy facilities that began
105 construction in 2015 and 2016. The legislation also provided for a phase-out of the PTC
106 over three years, reducing the PTC value by 20 percent for wind facilities beginning
107 construction in 2017, 40 percent for wind facilities beginning construction in 2018, and
108 60 percent for wind facilities beginning construction in 2019. The Internal Revenue
109 Service ("IRS") has issued guidance that establishes a "safe harbor" for taxpayers to
110 demonstrate the year a facility will be deemed to "begin construction," thereby setting
111 the value of the PTC. If at least five percent of the total project costs are incurred in
112 2016, then the facility qualifies under the IRS safe harbor for the full value of the PTC,
113 provided the taxpayer can demonstrate "continuous efforts" to complete construction.

¹ This range reflects increases under existing transmission interconnection agreements. The range is 15 percent to 38 percent if transmission interconnection agreements are modified to reflect the additional capacity available from the repowered turbines.

114 The IRS has issued additional guidance that establishes a safe harbor for satisfying this
115 continuous-efforts standard. Under the continuous-efforts safe harbor, the wind
116 facilities must be in service by the end of the fourth calendar year following the
117 calendar year in which construction began. Thus, wind facilities that began construction
118 in 2016 must be in service no later than December 31, 2020, to satisfy the continuous-
119 efforts safe-harbor provisions. If not installed by December 31, 2020, the projects must
120 satisfy IRS requirements that continuous-efforts were expended to repower the
121 facilities, which is a difficult standard to meet.

122 **Q. Does the Company’s repowering project qualify for the full value of the PTC**
123 **under these rules?**

124 A. Yes. Consistent with IRS guidance, a facility owner can demonstrate that construction
125 of a facility has begun in the year in which at least five percent of the applicable project
126 costs are incurred. If wind turbine equipment is purchased and delivered in 2016, and
127 the equipment comprises at least five percent of the applicable project costs, a PTC safe
128 harbor is created for the wind facilities subsequently constructed. To meet this
129 requirement, the Company executed safe-harbor equipment purchases with General
130 Electric International, Inc. (“GE”) and Vestas American Wind Technology, Inc. in
131 December 2016, and took delivery of equipment with a value sufficient to give the
132 Company the ability to repower its entire wind fleet and qualify the repowered wind
133 facilities for 100 percent of the PTC value.

134 **Q. What is the value of the PTC for wind facilities?**

135 A. For 2017, wind facilities that are qualified for the PTC receive 2.4 cents per kilowatt-
136 hour, or \$24 per megawatt-hour. This PTC value is adjusted annually based upon an

137 inflation index, and the PTC is available for energy produced during the 10-year period
138 after the wind facility begins commercial operation.

139 **Q. What other requirements must repowered projects satisfy to qualify for the PTC?**

140 A. On May 5, 2016, the IRS issued Notice 2016-31² (“Notice”), which provides guidance
141 on various aspects of qualifying for the PTC and whether new tax credits can be
142 claimed when wind turbines are repowered or retrofitted. The Notice generally
143 provides that the repowering costs must equal at least four times the fair market value
144 of the equipment that the owner retains from the original facility for the repowered
145 turbines to qualify for new PTCs. Thus, 80 percent of the fair market value of the
146 repowered WTG must result from repowering project costs while the value of the
147 retained components cannot exceed 20 percent of the fair market value of the new
148 facility. This “80/20” test is applied on a turbine-by-turbine basis. Each wind turbine—
149 composed of a foundation, tower, and machine head (including nacelle, hub and
150 rotor)—is considered a separate facility.

151 **Q. Do all of the wind turbines the Company is proposing to repower meet this 80/20**
152 **test?**

153 A. Yes. The repowering project has been scoped to ensure that the 80/20 test, which is
154 applied at the time the turbine is repowered, will be met for each turbine repowered.
155 Not all turbines at all wind facilities, however, will be repowered because the retained
156 value of the towers and foundations at certain wind turbines does not allow them to
157 meet the 80/20 test before the end of 2020, when the repowered wind facilities must be
158 completed to obtain the full PTC value.

² The IRS Notice 2016-31 is available at: https://www.irs.gov/irb/2016-23_IRB/ar07.html.

159 **Q. Which wind facilities will not have all wind turbines repowered?**

160 A. Repowering at Glenrock I, Rolling Hills and Glenrock III, located near Glenrock,
161 Wyoming, will not include all wind turbines. At this location, 32 of the 158 wind
162 turbines will not be repowered because the facilities were developed at the Company's
163 reclaimed Glenrock coal mine. These 32 wind turbines were constructed atop mine
164 tailings and required special pile foundations. These special foundations were more
165 expensive to construct than the standard foundations found elsewhere on those facility
166 sites and at other Company wind facility locations. Because the original construction
167 cost of these foundations was higher than for standard foundations, the retained value
168 of these foundations, which is based on net book value, is also higher than other
169 foundations. For these 32 wind turbine locations, the higher retained value of the
170 foundations means that repowering, while technically feasible, would not qualify those
171 turbines for PTCs, which is necessary for the repowering to be economic. The
172 Company plans to repower all of the turbines at the other wind facilities discussed
173 above.

174 **Q. How else has the Company scoped the repowering project to maximize the benefits**
175 **of available PTCs?**

176 A. As shown in Exhibit RMP____(TJH-2), the majority of the wind facilities the Company
177 proposes to repower, with the exception of Leaning Juniper, are still within 10 years of
178 their original commercial online date. Thus, the PTCs from original construction are
179 still accruing to the benefit of the Company's customers. The existing PTCs for these
180 wind facilities will expire 10 years after the facilities' commercial online date. Between
181 August 2017 and October 2020, the PTCs associated with approximately 2.64 terawatt-

182 hours (“TWh”) of electricity generated at the Company’s wind facilities will expire. On
183 an annual basis, in 2017 dollars, the expiration of these PTCs represents the loss of
184 approximately \$100 million per year in customer PTC benefits, as shown in Exhibit
185 RMP____(TJH-2).

186 To maximize the benefits of the existing PTCs available from the wind
187 facilities, the Company will generally delay repowering until the original PTCs have
188 expired. The exception to this is Dunlap, where the PTCs expire in October 2020. To
189 repower Dunlap by the end of 2020, as required to re-qualify for PTCs, repowering
190 must begin before October 2020 so construction can be completed before the winter
191 season. This results in a slight truncation of the existing, original 10-year PTC period
192 for that facility. As with all of the wind facilities, however, once Dunlap is repowered,
193 it will then re-start a 10-year period where its generation is eligible for the full value of
194 PTCs.

195 **INCREASED ENERGY BENEFITS FOLLOWING REPOWERING**

196 **Q. Once repowered, how do the energy benefits of the wind facilities increase?**

197 A. Repowering will involve the replacement of the existing machine heads including the
198 nacelle, hub and rotor. The new nacelles have generators that, in most instances, have
199 a greater nameplate generating capacity than the equipment that is removed. For
200 example, the nameplate of each turbine at the Wyoming facilities will increase from
201 1.5 MW to 1.6 MW, while at the Marengo facility, the generator nameplate rating will
202 increase from 1.8 MW to 2.0 MW. Details regarding the proposed wind turbine
203 upgrades, capital project costs, in-service dates, and resulting energy benefits are
204 shown in Confidential Exhibit RMP____(TJH-3).

205 In addition to the larger generators in the repowered turbines, the Company will
206 also install larger blades. With the larger blades, the rotor-swept area of the wind
207 turbines will increase between 28 to 56 percent, depending on the type of turbine. A
208 larger rotor-swept area allows more of the wind energy flowing past the wind turbine
209 to be captured and converted by the wind turbine into electricity. Because the size of
210 the rotors will increase, the repowered turbines will also include more robust hubs,
211 main shafts, bearings and couplings, and gearboxes suitable to handle the greater torque
212 exerted by the larger rotors.

213 **Q. Will the larger blades installed with repowering increase the potential for avian**
214 **impacts at the Wyoming wind facilities?**

215 A. Although the larger blades will increase the overall risk zone (rotor-swept area) of the
216 repowered wind turbines, this does not necessarily correlate with an increased risk of
217 avian impacts at existing turbine sites. The Company will continue to implement its
218 current informed-curtailment protocols after repowering to minimize avian impacts.
219 Informed curtailment involves the shutdown of wind turbines when species of interest
220 are in the vicinity. The Company's informed-curtailment protocols avoid avian impacts
221 regardless of the swept area of the rotor. The Company performs monthly monitoring
222 at all Wyoming wind facilities and reports all findings to both the Wyoming Game and
223 Fish Department and the U.S. Fish and Wildlife Service. The Company will continue
224 this monthly monitoring to determine if the new turbine blades cause additional impacts
225 to avian species and will engage with the appropriate agency to discuss and, if prudent
226 and practicable, implement additional avoidance, minimization, or mitigation
227 measures.

228 **Q. How did the Company determine the amount of additional generation that will be**
229 **produced from the repowered wind turbines?**

230 A. The Company retained the engineering consulting firm of Black & Veatch, Inc. (“Black
231 & Veatch”) to evaluate increased energy production expected at each of the wind
232 facilities from repowering. To complete this assessment, Black & Veatch used site wind
233 data, wind turbine location data, operational performance data, and other available site-
234 specific information for each facility to model this increased generation. The wind
235 model also evaluated generation losses resulting from the wake losses at each turbine
236 location. Wake losses are the reduction in generation at turbines downwind of other
237 turbines due to reduced wind speed and increased turbulence in the airflow—or wake—
238 behind a turbine.

239 **Q. What are the major power production advantages of the new equipment?**

240 A. The larger rotor size and improvements in blade design of the new equipment generate
241 more power at all ranges of wind speeds. Additionally, some of the new turbines begin
242 producing power at a lower wind speed than the existing equipment; thus, the turbines
243 can produce energy during lower wind conditions in which the current equipment may
244 sit idle. Because the new turbines, at most facilities, will have an increased generator
245 capacity, the turbines will also produce more energy when wind speeds are high and
246 the turbines are at their maximum output. These power production advantages are
247 illustrated in Exhibit RMP____(TJH-4). This exhibit compares the power curves of an
248 existing wind turbine to those of a repowered wind turbine.

249 **Q. Why wasn't this larger equipment installed when the wind facilities were initially**
250 **constructed?**

251 A. Wind turbine technology has continued to advance since the facilities were first
252 constructed between 2006 and 2010. The use of new composite materials has allowed
253 blade lengths to increase without adding weight, allowing for the extraction of more
254 energy from the available wind resources at the facility sites. In addition, more
255 sophisticated sensor and control systems in the wind turbines, combined with improved
256 blade pitch control systems, increase the ability of the wind turbine control systems to
257 implement load mitigation strategies on the wind turbines to reduce the loading on the
258 power train, towers and foundations. For new wind facilities, these technology
259 improvements mean that longer blades and additional generating capacity is possible
260 without a commensurate increase in cost to strengthen the turbine structural
261 components (including the tower and foundation). For new wind facilities, this is one
262 of the drivers towards reduced energy costs. For existing wind facilities, these new load
263 mitigation technologies mean that the existing towers and foundations are suitable for
264 the installation of larger equipment through repowering.

265 **Q. How much additional energy will the repowered wind facilities produce?**

266 A. As shown in Confidential Exhibit RMP____(TJH-3), across the wind fleet, the proposed
267 repowered wind facilities are estimated to increase generation by 550,601 megawatt-
268 hours ("MWh") per year if the facilities are operated within the limits of their existing
269 large generator interconnection agreements—an increase of 19 percent. If the facilities
270 are operated at their full generating capability following a modification to their

271 interconnection agreements, the additional generation increases to 597,671 MWh per
272 year, or an increase of 21 percent.

273 **Q. Is the Company planning to use the additional generating capacity provided by**
274 **the repowered wind turbines?**

275 A. Yes. The Company has submitted generation interconnection applications to request
276 increased output from the repowered wind facilities and transmission service requests
277 to transmit power so that the full generation capability of the repowered facilities can
278 be delivered to customers.

279 **Q. Is the repowering project economic even without the ability of the wind facilities**
280 **to generate at their full repowered nameplate capacity?**

281 A. Yes, as Company witness Mr. Rick T. Link demonstrates in his testimony, the
282 repowering projects are economic even if the facilities are operated within their existing
283 transmission capacity limits. An adjustment to the large-generator interconnection
284 agreements allows the facilities to be operated at full nameplate capability following
285 repowering and simply improves the economics of the repowering project.

286 **Q. With the rapid technological advances in the wind industry, will the Company be**
287 **able to leverage any advancements for the repowering projects before the new**
288 **equipment is installed?**

289 A. Yes. Turbine manufacturers continue to develop new technologies and offerings to
290 improve efficiency and reliability and reduce the overall cost of wind energy—both for
291 new and repowered facilities. To the extent the Company’s repowering projects can
292 leverage these advancements, the Company will evaluate them and negotiate with the
293 turbine suppliers to incorporate new product offerings to further enhance the benefits

294 of the repowering the facilities for customers. For example, GE is developing a 91-
295 meter rotor for repowering projects like the Company's that is based upon the proven
296 designs of its existing rotor offerings. This new rotor will be compatible with the safe-
297 harbor equipment the Company purchased in December 2016, and with the nacelles the
298 Company is purchasing as follow-on equipment consistent with the contract with GE.
299 This new rotor, if it can be applied to the Company's repowering project, would further
300 increase the amount of energy produced as a result of repowering, resulting in
301 additional customer benefits.

302 **REDUCED ONGOING OPERATIONAL COSTS FOLLOWING REPOWERING**

303 **Q. Aside from increased generation and the associated PTC benefits, what other**
304 **benefits will be realized with the repowering project?**

305 A. The repowering project will lower the ongoing costs of operating the existing wind
306 facilities. The Company's turbine-supply contracts for repowering, consistent with
307 wind industry standards for new equipment, will include a two-year warranty on the
308 new equipment. This will reduce capital costs associated with replacing or refurbishing
309 the equipment currently in service. Additionally, the new turbine equipment associated
310 with repowering, will obviate, to a large extent, capital costs associated with major
311 turbine component replacements and refurbishments (generators, gearboxes, blades,
312 and small components). After the two-year warranty period for the new equipment
313 expires, these costs are expected to be lower than the costs for the current equipment
314 that has now been in service for up to 11 years. Further, capital costs will be reduced
315 before repowering as the investment horizon for the existing wind turbines closes and

316 various capital replacements no longer make economic sense given the short remaining
317 installed life of the turbines to be repowered.

318 **Q. Will the Company's reduced capital investments during the transition to**
319 **repowering cause a reduction in the generation from the facilities?**

320 A. Yes, before repowering is complete, some of the existing turbines may experience
321 component failures that render them unable to provide economic service. It will be
322 more economic for customers to idle these turbines than repair them given the short
323 period before repowering. As a result, the Company estimates that generation from the
324 wind facilities targeted for repowering will be reduced before repowering. These
325 pre-repowering generation impacts are factored into the economic analysis.

326 **Q. Will the new equipment address any other operational cost issues?**

327 A. Yes. In addition to the reduced capital run rate of the new equipment in its early years
328 after installation, repowering will avoid costs from replacing certain major turbine
329 components that are experiencing high failure rates. One category of avoided costs
330 relates to failures of certain models of gearboxes found in the Wyoming wind fleet and
331 Leaning Juniper and Marengo. These gearboxes, which are original equipment from
332 the manufacturer, are experiencing high failure rates compared to other models of
333 gearboxes installed in WTGs at these facilities and elsewhere within the wind fleet.
334 Consequently, the Company has experienced increased capital costs in recent years to
335 address the gearbox failures, and these models are no longer being re-installed as long-
336 term replacement equipment after failure, given their poor historical performance.

337 **Q. Why are these gearbox failures significant?**

338 A. These gearbox failures generally cannot be repaired "up-tower." The repair cannot be

339 completed within the nacelle without removing the damaged equipment by crane.
340 These failures cost approximately \$400,000 per occurrence, including equipment and
341 labor costs to purchase and install a replacement gearbox and the costs of mobilizing a
342 large crane to the site to remove and replace the equipment. These costs also do not
343 account for the lost generation from the time the turbine is down until the repair is
344 completed.

345 **Q. How many gearbox failures of this type are expected if there is no repowering?**

346 A. There are 230 of these gearbox models remaining in the wind fleet, and the Company
347 anticipates that all of these remaining gearboxes will fail within the next 15 years.

348 **Q. Will repowering completely address these gearboxes with shorter-than-**
349 **anticipated service lives?**

350 A. No. Ten of the 32 wind turbines that will not be repowered at Glenrock I, Glenrock III,
351 and Rolling Hills have these gearbox models that will need to be replaced, which is
352 factored into the economic analysis. Following repowering, these gearboxes—as well
353 as potential failures of other gearbox models at the non-repowered units—can be
354 replaced with those removed from the existing turbines as part of the repowering effort,
355 reducing the repair costs of the remaining gearboxes. The cost savings of doing so,
356 however, have not been factored into the Company’s economic analysis because the
357 Company is still evaluating how best to realize value for customers from the removed
358 equipment.

359 **Q. Are other significant capital costs avoided with repowering?**

360 A. Aside from the gearbox issues, repowering will also avoid ongoing capital expenditures
361 related to blade costs at Goodnoe Hills. Blade expenditures at this facility represent

362 approximately 60 percent of the budgeted capital costs associated with blade failures
363 and refurbishments across the Company's wind fleet, even though Goodnoe Hills
364 accounts for only seven percent of the turbines. Repowering is expected to bring blade
365 costs for that facility in line with the Company's expenditures at its other facilities,
366 resulting in reduced capital costs to keep the wind fleet meeting its operational
367 performance targets.

368 Given these ongoing gearbox and blade failure costs, repowering is particularly
369 attractive because repowering avoids significant forecast capital expenditures to
370 maintain turbine production. This addresses the predicted turbine failure, replaces the
371 turbine equipment with new equipment that extends the asset life, and provides the
372 benefit of increased generation from the turbine, while requalifying the wind turbine
373 for PTCs for another 10-year period.

374 **Q. Will the new repowering equipment have similar failure issues as the old**
375 **gearboxes?**

376 A. No. The gearbox models in the fleet that are experiencing high failure rates will not be
377 included in the equipment installed for repowering because the gearbox specifications
378 for the new equipment differ from the existing equipment. Thus, the Company does not
379 expect to see these same gearbox models and their attendant reliability concerns.
380 Further, the equipment that will be installed has evolved from the product lines of the
381 existing turbines, rather than arising from new product offerings. Thus, the turbine
382 suppliers have presumably learned from past experience with these turbine models and
383 made adjustments in their designs, specifications, and choice of subcomponent
384 suppliers to enhance turbine reliability. Because of the warranty service requirements

385 in the turbine-supply contracts and because the turbine suppliers are often under long-
386 term service agreements for the turbines they supply, the turbine suppliers have an
387 incentive to improve the reliability of their turbines.

388 **MAINTAINING TRANSMISSION SYSTEM RELIABILITY**

389 **Q. With the high concentration of wind in eastern Wyoming, and the increased wind**
390 **turbine capacity from the repowering project, what measures are being taken by**
391 **the Company to assure continued transmission system reliability?**

392 A. In addition to adding new transmission infrastructure necessary to support the new
393 wind resources that are the subject of the concurrently filed application for approval of
394 the resource decision for transmission and new wind, the Company has identified the
395 need to add two features to the wind turbine capabilities of the repowered facilities that
396 will improve the reliability of the transmission system for eastern Wyoming. These
397 reliability features will provide added support for system voltages during a wide range
398 of operating conditions and increased system inertia to provide needed transmission
399 system support during under-frequency system events.³ These two features are
400 summarized below and will be installed on the repowered units of the GE wind fleet in
401 Wyoming:

- 402 • The WindFREE™ Reactive Power feature has been developed by GE for wind
403 turbines to provide smooth fast voltage regulation by delivering controlled
404 reactive power through all operating conditions. By supervising individual wind
405 turbines, the WindCONTROL™ system ensures that the reactive power
406 performance of a wind power plant can meet—and often exceed—the

³ Under-frequency events occur when imbalances in system generation resources and load cause transmission system frequency to drop below 60 hertz, which can result in load shedding to restore system frequency.

407 performance of a conventional (non-wind) power plant. Even when wind
408 turbines are not generating active power, GE's wind turbine generators
409 equipped with the WindFREE™ Reactive Power control feature can provide
410 reactive power. The provision of continued voltage support and regulation
411 provides grid benefits not possible with conventional generation, while
412 mitigating adverse voltage impacts of wind turbines being off-line due to wind
413 conditions. This feature can eliminate the need for grid reinforcements
414 specifically designed for no-wind conditions, and may allow for more economic
415 commitment of other generating resources that will enhance grid security by
416 reducing the risk of voltage collapse.

417 • The WindINERTIA™ control has been developed by GE to provide an inertial
418 response capability for wind turbines that is similar to that of conventional
419 synchronous generators during under-frequency grid events. By utilizing the
420 mechanical inertia of the rotor, GE has designed the WindINERTIA™ power
421 pulse characteristics to provide a five percent to 10 percent increase in turbine
422 power over operational wind speeds. The duration of the power pulse is up to
423 several seconds and benefits the grid by allowing other non-wind power
424 generation assets time to respond by increasing power production.

425 **Q. Are these features part of the current Wyoming GE wind fleet?**

426 A. No, but with the additional capacity from repowering, and the increased amount of
427 wind generation anticipated as part of the Company's current CPCN application, the
428 Company believes these features will provide important system support capabilities
429 after the facilities are repowered.

430 **Q. How will these features benefit customers?**

431 A. These features will improve transmission system reliability and will allow the
432 Company greater flexibility in managing the transmission system in Wyoming. These
433 features should defer the need to separately provide for transmission system voltage
434 support through the construction of synchronous condensers or static VAr (volt-amp
435 reactive) compensators.

436 **Q. Have these reliability and deferred transmission system support costs been**
437 **factored into the economic analysis of the repowering project?**

438 A. No, these customer benefits are not currently included in the economic analysis because
439 transmission studies are needed to quantify these benefits as compared to other
440 alternatives. The Company is currently undertaking these studies.

441 **EXTENSION OF WIND FACILITY ASSET LIFE AFTER REPOWERING**

442 **Q. What is the current asset life of the wind facilities that will be repowered?**

443 A. All of the existing wind facilities are currently being depreciated assuming a 30-year
444 asset life. The facilities the Company plans to repower are currently scheduled to be
445 retired between 2036 and 2040.

446 **Q. Will repowering the wind facilities extend their useful operating lives beyond the**
447 **currently planned retirement dates?**

448 A. Yes, repowering the wind facilities will extend their life an additional 30 years from
449 the repowering date, extending their useful lives by at least 10 years.

450 **Q. How will repowering extend the useful life for an additional 30 years?**

451 A. The repowering projects are being designed by the turbine equipment suppliers to meet
452 the same design requirements that apply to complete wind turbine generators used in

453 new wind facility construction. The wind turbine equipment suppliers are contractually
454 required, as would be the case with a new wind facility, to have their wind turbine
455 designs for the repowering projects certified by an independent third party to ensure
456 that they meet or exceed applicable International Electrotechnical Commission design
457 standards used in the wind turbine industry. These design standards are intended to
458 ensure that the equipment is appropriate for the site conditions and will perform
459 satisfactorily over the standard design life.

460 **Q. What factors will be independently reviewed to assess and certify the design?**

461 A. The third-party design assessment evaluates the site-specific load assumptions based
462 upon the climactic conditions at each facility and will assess the control and protection
463 systems for the wind turbine and their ability to meet the site design conditions. It will
464 also assess the electric components, the rotor blades, hub, machine components (*i.e.*,
465 drivetrain, main bearing and gearbox), and the suitability of the existing tower upon
466 which the new wind turbine equipment will be installed.

467 **Q. Does the design certification also evaluate the ability of the existing foundations
468 to handle the loads associated with the repowered turbines?**

469 A. No. The design certification will assess the design loads and the design assumptions
470 regarding the ability of the new turbines and the existing towers to handle those loads.
471 But as with new wind facility development, the facility owner must provide a
472 foundation suitable to handle the loads imparted by the tower on the foundation.

473 **Q. Has the Company reviewed the foundations to ensure they are capable of handling
474 the new turbines?**

475 A. Yes. The Company retained Black & Veatch to evaluate the ability of the existing

476 foundations to handle the loads of the repowered turbines. For the Wyoming facilities
477 and Marengo I and Marengo II, which have been fully designed, Black & Veatch's
478 evaluation indicates that the existing foundations are suitable for the repowered
479 turbines. For Leaning Juniper and Goodnoe Hills, foundation load evaluations have not
480 yet been completed because those facilities are still under design review, which is
481 expected to be completed by this fall. The suitability of the foundations will be
482 confirmed when the design process is completed for those facilities and before
483 executing contracts. Because of the load-mitigation controls now available with newer
484 equipment, the future foundation loads at some of the facilities, even with the larger
485 equipment, are less than the original design loads the foundations were engineered to
486 withstand.

487 **Q. Has the Company evaluated the foundations to determine if they are suitable for**
488 **an additional 30-year service life following repowering?**

489 A. Yes, for the foundations in which fatigue loading is a controlling design variable, and
490 for which foundation load specifications are now available, the Company's consultant
491 assessed the ability of the foundations to handle the estimated fatigue loading
492 anticipated from an additional 30-year life following repowering and determined the
493 foundations are able to accommodate the additional loading.

494 **PROJECT CONTRACT STATUS AND CONSTRUCTION SCHEDULE**

495 **Q. What is the status of contracting related to the proposed repowering projects?**

496 A. For the facilities that will be repowered with GE equipment, the Company is
497 negotiating a turn-key master retrofit contract with GE to perform the repowering at a
498 fixed price per turbine. This fixed-price contract will provide the Company the ability

499 to execute retrofit work orders for the facilities to be repowered and will significantly
500 mitigate cost uncertainty related to the facilities. For the facilities that will be
501 repowered with Vestas equipment, the Company executed a master turbine-supply
502 agreement on December 28, 2016, that facilitates future equipment supply in support
503 of repowering, and will negotiate an installation contract with Vestas or with other
504 qualified wind energy contractors.

505 **Q. When must the Company execute contracts with the equipment suppliers to**
506 **proceed with the repowering projects?**

507 A. Under the terms of the master retrofit contract being negotiated with GE, for
508 repowering projects to be completed before March 31, 2020, the Company must notify
509 GE of its intent to execute a retrofit work order eight months before the date requested
510 by the Company for commissioning of the first retrofitted unit for any facility. For
511 repowering projects to be completed on or after March 31, 2020, the Company must
512 notify GE of its intent to execute a retrofit work order 12 months before the date
513 requested by the Company for completion of commissioning of the first retrofitted unit
514 for that project. Similarly, the Company will need to execute a contract with Vestas 12
515 months before equipment deliveries begin for a particular repowering project. The
516 Company's construction schedule has been developed to optimize the PTC benefits of
517 the facilities and ensure that the facilities can be constructed during the low-wind
518 season—between March and November. To meet the equipment supply lead times
519 requires contract execution beginning in early April 2018. Allowing time to finalize
520 and execute the repowering contracts, the Company must be in a position by March

521 2018 to proceed with these facilities. A detailed project schedule for the repowering
522 projects is attached as Exhibit RMP____(TJH-5).

523 **Q. Why is there such a long lead time between the execution of retrofit contracts and**
524 **the time that turbines can actually be repowered or delivered to the site to support**
525 **the repowering projects?**

526 A. Like all equipment suppliers in the wind industry, both GE and Vestas are currently
527 responding to unprecedented demand to supply equipment for wind facilities that are
528 slated to be installed before December 31, 2020, to qualify the facilities for the full
529 value of the PTC. Because this equipment is manufactured to order, long lead times are
530 required to ensure manufacturing capacity is available and to meet specific project
531 delivery requirements. In some cases, additional manufacturing capacity may need to
532 be sourced or constructed to meet the equipment supply demands.

533 **Q. Aside from manufacturing lead times, are there other drivers for the lead times**
534 **associated with constructing these facilities?**

535 A. Yes, in addition to the manufacturing constraints, lead times are necessary to ensure
536 that construction contractors and work crews and cranes are available to install the
537 repowering equipment. Because of the large-scale efforts involved in repowering the
538 facilities, these resources must be secured well in advance of project construction to
539 ensure project schedules are met. Also, both skilled labor resources and construction
540 cranes are likely to be in short supply given the amount of activity involved in new
541 wind facility construction and wind repowering projects across the country that must
542 achieve commercial operation by December 31, 2020, to meet the safe-harbor rules
543 summarized above in my testimony to qualify for the full value of the PTC. Thus,

544 securing these necessary resources well before beginning these time-sensitive projects
545 mitigates both cost and schedule risk for these beneficial projects.

546 **Q. How has the Company designed the repowering projects to work within these**
547 **constraints?**

548 A. As discussed above, the 2019 construction schedule for most of the facilities, other than
549 Dunlap, optimizes the existing PTC benefits of the facilities and also allows for their
550 construction, generally, more than a year in advance of the December 31, 2020 deadline
551 to achieve commercial operation.

552 **Q. What permitting requirements apply to repowering projects and what steps has**
553 **the Company taken to acquire any needed regulatory approvals for the**
554 **repowering projects?**

555 A. Because repowering does not increase the footprints of the existing wind facilities, and
556 since the facilities are operating under current local, state and federal permits and
557 authorizations, the permitting requirements for repowering are minimal. Because the
558 facility footprints are not altered and since repowering is unlikely to disturb additional
559 acreage not already covered by existing permits, additional standard construction
560 permits, such as storm-water permits and fugitive dust permits, are likely not required.
561 Throughout the repowering process the Company will ensure that the requirements of
562 the existing permits and authorizations are met, and will provide needed information to
563 permitting authorities to amend or modify the existing permits for the facilities to
564 reflect the change in turbine equipment, if needed. This involves assessing whether
565 amendments to the existing Wyoming Industrial Siting Division (“ISD”) permits are
566 required to reflect the new wind turbine equipment installed in Wyoming, as well as

567 similar processes to amend existing county authorizations in other states, as well as
568 modifications to Federal Aviation Administration authorizations to reflect the increased
569 height of the turbine blades.

570 The Company has engaged with the Wyoming ISD to determine requirements
571 for performing the repowering activities and based on those discussions, no additional
572 permitting or permit amendments are anticipated, as the repowering efforts can be
573 performed as operations and maintenance activities under the existing permits.
574 Additionally, the Company has spoken with county authorities to determine local
575 permitting requirements. Based on those discussions, the Company has identified the
576 need for new building permits and/or amendments to existing county authorizations in
577 several counties. The Company will obtain these permits/amendments before
578 beginning the repowering project. The Company will continue to work with the
579 appropriate regulatory and permitting authorities to provide information necessary to
580 obtain any needed permits or to process any amendments or modifications to the
581 existing facility permits.

582 **DISPOSITION OF REMOVED EQUIPMENT**

583 **Q. What is the Company planning to do with the existing equipment that will be**
584 **removed?**

585 A. The Company has not yet determined how it will dispose of this equipment, but will
586 explore various options to realize the greatest customer benefit from the equipment.
587 Because the Company will be replacing the entire machine head (nacelle, hub, and
588 rotor) of the repowered turbines, the removed equipment has the potential to be reused
589 and redeployed to another site location. This may make the equipment valuable for

590 redeployment elsewhere in the country, or perhaps elsewhere in North America.

591 The Company understands that a significant number of turbines of all makes
592 and models will be repowered before 2020. This creates potential value for the removed
593 equipment as spare parts for similar type turbines that will remain in service. This also
594 makes it difficult, however, to use current market pricing for used turbines as a proxy
595 for the potential salvage value of the equipment given the large number of repowered
596 turbines and associated spare parts that will become available in the next several years.
597 Because not all the Company's GE turbines will be repowered, some of the equipment
598 can potentially be used as spare parts to service the non-repowered turbines.

599 **Q. Given the uncertainty of the market for the removed equipment either for**
600 **redeployment or as spare parts, what was assumed in the economic analysis for**
601 **the salvage value of the equipment?**

602 A. The Company did not assume any salvage value for the removed equipment in its
603 economic analysis, which is a conservative assumption given the potential for the
604 equipment to be reused, repurposed as spare parts, or merely salvaged for scrap metal
605 value. To the extent the Company determines any salvage value by reusing the
606 equipment, or by selling or auctioning it to third parties, the Company will pass through
607 any and all additional financial benefits to its customers.

608 **SUMMARY AND CONCLUSION**

609 **Q. Please summarize your testimony.**

610 A. The wind repowering project presents the opportunity to leverage prior investments in
611 the wind fleet and enhance its future value for customers. By executing wind turbine
612 equipment purchases in late 2016, the Company was able to secure the opportunity to

613 repower and renew the wind fleet and deliver the maximum value of these facilities to
614 customers by qualifying for the full value of the PTC. Repowering now provides a
615 unique opportunity to return the Company's wind turbines to like-new condition while
616 enhancing their performance and avoiding expenditures that maintain but do not
617 enhance the value of the wind fleet.

618 By incorporating recent technical advances that allow for longer blades to be
619 installed on the existing towers and foundations, repowering will result in significantly
620 more low-cost energy for customers—550 TWh annually, or an increase of 19 percent.
621 With increases to the allowable transmission capacity of the facilities, these generation
622 benefits will be 598 TWh, or an increase of 21 percent. If new equipment now being
623 developed by GE for repowering projects can be successfully applied to these facilities,
624 generation will be further increased with resulting benefits to customers. Further,
625 repowering with new equipment will extend the asset lives of the wind facilities by at
626 least 10 years—allowing the wind facilities to continue serving customers well into the
627 future.

628 Finally, these benefits from repowering can be delivered to customers while
629 reducing rather than increasing costs to customers, as further described by Company
630 witness Mr. Link.

631 **Q. What is your recommendation to the Commission?**

632 A. I recommend the Commission enter a finding that the decision to repower certain wind
633 facilities is prudent and in the public interest and approve the Application as filed,
634 including the request for continued cost recovery of the wind equipment that will be

635 replaced and the proposed rate-making treatment for the new costs and benefits of the
636 wind repowering project.

637 **Q. Does this conclude your direct testimony?**

638 A. Yes.