

**ROCKY MOUNTAIN POWER
ELECTRIC SERVICE REGULATION NO. 6
STATE OF UTAH**

Company's Installation

1. COMPANY'S INSTALLATION

Except as otherwise provided in these Regulations, an Electric Service Agreement, or the Electric Service Schedules, the Company will install and maintain its lines and equipment on its side of the Point of Delivery, but shall not be required to install or maintain any lines or equipment except meters and accessories beyond that point. Only the Company is authorized to make the connections at the Point of Delivery. Electric service furnished under this tariff will be alternating current, 60 hertz, single or three-phase. Primary service voltage will be at one of the nominal standard voltages available from the Company at or near the Customer's location. Secondary service voltage will be limited to:

- Single-phase, 120 volts, 2-wire, grounded
- Single-phase, 120/240 volts, 3-wire, grounded
- Single-phase, 240/480 volts, 3-wire, grounded
- Three-phase, 208Y/120 volts, 4-wire, grounded, wye
- Three-phase, 480Y/277 volts, 4-wire, grounded, wye

2. COMPANY FACILITIES ON CUSTOMER'S PREMISES

- (a) All materials furnished and installed by the Company on the Customer's premises, shall be, and remain, the property of the Company. The Customer shall not break the Company's seals. In the event of loss or damage to the Company's property, arising from neglect, carelessness, or misuse by the Customer, the cost of necessary repairs or replacement shall be paid by the Customer.
- (b) Customer without expense to the Company shall make or procure conveyance to the Company of satisfactory Rights-of-Way Easements across the property owned or controlled by the Customer for the Company's lines or extensions thereof necessary or incidental to the furnishing of service to the Customer.
- (c) The Customer shall provide safe, unobstructed access to Company representatives at all hours to maintain the Company's electric distribution facilities. The Customer shall also permit the Company to trim trees and other vegetation to the extent necessary to avoid interference with the Company's lines and to protect public safety. Safe and unobstructed access is defined as free of any obstructions including, but not limited to, obstructions caused by structures, trees, vegetation, landscaping, equipment or vehicles, driveways or installed foundations, debris or animals.

ELECTRIC SERVICE REGULATION NO. 6 - Continued

- (d) The Customer shall provide safe, unobstructed access to Company representatives at reasonable times, for the purpose of reading meters, inspecting, repairing or removing metering devices and wiring of the Company. Safe and unobstructed access is defined as free of any obstructions including, but not limited to, obstructions caused by structures, trees, vegetation, landscaping, equipment or vehicles, driveways or installed foundations, debris or animals.