



Joelle R. Steward
Vice President, Regulation
1407 W. North Temple, Suite 330
Salt Lake City, UT 84116

January 15, 2020

***VIA ELECTRONIC FILING
AND OVERNIGHT DELIVERY***

Chris Petrie
Secretary and Chief Counsel
Wyoming Public Service Commission
2515 Warren Avenue, Suite 300
Cheyenne, Wyoming 82002

**RE: Compliance Filing, Tariff Rule 6
Docket No. 20000-567-ET-19, Record No. 15349**

Dear Mr. Petrie:

Pursuant to the Wyoming Public Service Commission decision from the January 7, 2020 open meeting in this docket, please find enclosed the tariff sheets that were approved that include the name of the Vice President of Regulation for Rocky Mountain Power. The effective date will be January 7, 2020.

Informal questions may be directed to Stacy Splittstoesser, (307) 632-2677.

Sincerely,

Joelle R. Steward
Vice President, Regulation

Enclosure

ROCKY MOUNTAIN POWER

~~First-Second~~ Revision of Sheet No. R6-1
Canceling ~~Original Sheet-First Revision of~~ No. R6-1

P.S.C. Wyoming No. 16

Company's Installation Rule 6

I. Company's Installation

The Company will install and maintain the electric lines and equipment on the Company's side of the Point of Delivery. It will only maintain its meters and accessories beyond that point. Only the Company is authorized to make the connections at the Point of Delivery.

The equipment the Company installs on the Customer's premises remains the property of the Company. If the Company's equipment is lost or damaged because of the Customer's neglect, carelessness, or misuse, the Customer will pay the cost of repairs or replacement.

The Customer will allow the Company safe, unobstructed access to the Customer's premises, at reasonable times, to read meters, to inspect and repair facilities, to connect, disconnect or terminate service, and to trim trees and other vegetation to the extent necessary to avoid interference with the Company's lines and to protect public safety.

II. Description of Service

A. General

The Company supplies alternating current at 60 hertz, single-phase or three-phase, at one of the voltages listed in **B.** below. The Company may limit the maximum or minimum load served at any of these voltages.

B. Standard Voltages

1. Secondary Service Voltages

Single-phase, 120 volts, 2-wire, grounded

Single-phase, 120/240 volts, 3-wire, grounded

~~Single-phase, 240/480 volts, 3-wire, grounded~~

Three-phase, 208Y/120 volts, 4-wire, grounded

Three-phase, 480Y/277 volts, 4-wire, grounded

(continued)

Issued by

~~Jeffrey K. Larsen, J~~Joelle R. Steward, Vice President, Regulation

Issued: ~~October 27, 2017~~January 15, 2020

Effective: With service rendered
on and after ~~September 12, 2017~~January 7, 2020

ROCKY MOUNTAIN POWER

Second Revision of Sheet No. R6-1
Canceling First Revision of No. R6-1

P.S.C. Wyoming No. 16

Company's Installation Rule 6

I. Company's Installation

The Company will install and maintain the electric lines and equipment on the Company's side of the Point of Delivery. It will only maintain its meters and accessories beyond that point. Only the Company is authorized to make the connections at the Point of Delivery.

The equipment the Company installs on the Customer's premises remains the property of the Company. If the Company's equipment is lost or damaged because of the Customer's neglect, carelessness, or misuse, the Customer will pay the cost of repairs or replacement.

The Customer will allow the Company safe, unobstructed access to the Customer's premises, at reasonable times, to read meters, to inspect and repair facilities, to connect, disconnect or terminate service, and to trim trees and other vegetation to the extent necessary to avoid interference with the Company's lines and to protect public safety.

II. Description of Service

A. General

The Company supplies alternating current at 60 hertz, single-phase or three-phase, at one of the voltages listed in **B.** below. The Company may limit the maximum or minimum load served at any of these voltages.

B. Standard Voltages

1. Secondary Service Voltages

Single-phase, 120 volts, 2-wire, grounded
Single-phase, 120/240 volts, 3-wire, grounded
Single-phase, 240/480 volts, 3-wire, grounded
Three-phase, 208Y/120 volts, 4-wire, grounded
Three-phase, 480Y/277 volts, 4-wire, grounded

(continued)

Issued by
Joelle R. Steward, Vice President, Regulation

Issued: January 15, 2020

Effective: With service rendered
on and after January 7, 2020