

ROCKY MOUNTAIN POWER

Original Sheet No. R6-1

P.S.C. Wyoming No. 17

Company's Installation Rule 6

I. Company's Installation

The Company will install and maintain the electric lines and equipment on the Company's side of the Point of Delivery. It will only maintain its meters and accessories beyond that point. Only the Company is authorized to make the connections at the Point of Delivery.

The equipment the Company installs on the Customer's premises remains the property of the Company. If the Company's equipment is lost or damaged because of the Customer's neglect, carelessness, or misuse, the Customer will pay the cost of repairs or replacement.

The Customer will allow the Company safe, unobstructed access to the Customer's premises, at reasonable times, to read meters, to inspect and repair facilities, to connect, disconnect or terminate service, and to trim trees and other vegetation to the extent necessary to avoid interference with the Company's lines and to protect public safety.

II. Description of Service

A. General

The Company supplies alternating current at 60 hertz, single-phase or three-phase, at one of the voltages listed in **B.** below. The Company may limit the maximum or minimum load served at any of these voltages.

B. Standard Voltages

1. Secondary Service Voltages

- Single-phase, 120 volts, 2-wire, grounded
- Single-phase, 120/240 volts, 3-wire, grounded
- Single-phase, 240/480 volts, 3-wire, grounded
- Three-phase, 208Y/120 volts, 4-wire, grounded
- Three-phase, 480Y/277 volts, 4-wire, grounded

(continued)

Issued by
Joelle R. Steward, Vice President, Regulation

Issued: June 25, 2021

Effective: With service rendered
on and after July 1, 2021

ROCKY MOUNTAIN POWER

Original Sheet No. R6-2

P.S.C. Wyoming No. 17

Company's Installation Rule 6

B. Standard Voltages (continued)

2. Alternative Secondary Service Voltages

At the Company's option, it may provide three-phase, 120/240 volts, 4-wire service, grounded; and three-phase 480 volts, 3-wire service, ungrounded (overhead only).

3. Primary Voltages

Three-phase, 12470Y/7200 volts, 4-wire, grounded
Three-phase, 13200Y/7620 volts, 4-wire, grounded
Three-phase, 20800Y/12000 volts, 4-wire, grounded
Three-phase, 24900Y/14400 volts, 4-wire, grounded
Three-phase, 34500Y/19900 volts, 4-wire, grounded

The Company will deliver primary or greater voltage upon availability and the Customer signing a written contract.

Issued by
Joelle R. Steward, Vice President, Regulation

Issued: June 25, 2021

Effective: With service rendered
on and after July 1, 2021

WY_R6-2.E

Dkt. No. 20000-578-ER-20