

## INCENTIVES FOR HVAC EQUIPMENT

EQUIPMENT TYPE	CATEGORY	SUB-CATEGORY	MINIMUM EFFICIENCY REQUIREMENT & CUSTOMER INCENTIVE		
			\$25/TON	\$50/TON	\$75/TON
Unitary Commercial Air Conditioner	Air cooled	< 65,000 Btu/hr		CEE Teir 2	CEE Advanced Tier
		≥ 65,000 btu/hr and < 135,000 btu/hr			
		≥ 135,000 btu/hr and < 240,000 btu/hr			
		≥ 240,000 btu/hr and < 760,000 btu/hr			
		≥ 760,000 btu/hr		CEE Tier 2	
	Water cooled	All equipment sizes		CEE Tier 2	
	Evaporatively Cooled				
Unitary Commercial Heat Pumps (See note 3)	Water cooled	All equipment sizes		CEE Tier 1	
	Ground source	All equipment sizes		ENERGY STAR <sup>®</sup> qualified	
	Groundwater source	All equipment sizes		ENERGY STAR <sup>®</sup> qualified	
	Groundwater Source, Open Loop				
	Air cooled	< 65,000 Btu/hr		ENERGY STAR <sup>®</sup> qualified	
		≥ 65,000 btu/hr and < 240,000 btu/hr			
Packaged Terminal Air Conditioners (PTAC)	—	≤ 8,000 Btu/hr	13 EER		
		> 8,000 Btu/hr and < 10,500 Btu/hr	12.1 EER		
		≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	11.6 EER		
		> 13,500 Btu/hr	10.4 EER		
Packaged Terminal - Heat Pumps (PTHP) (See note 3)	—	≥ 8,000 Btu/hr		13.0 EER and 3.6 COP	
		> 8,000 Btu/hr and < 10,500 Btu/hr		12.1 EER and 3.5 COP	
		≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr		11.6 EER and 3.5 COP	
		> 13,500 Btu/hr		10.4 EER and 3.3 COP	

(continued)

## INCENTIVES FOR HVAC EQUIPMENT (CONTINUED)

EQUIPMENT TYPE	CATEGORY	SUB-CATEGORY	CUSTOMER INCENTIVE
VRF Heat Pumps (See note 3)	Air cooled	Multisplit system, all equipment sizes	CEE Teir 1 \$125/ Ton
		Multisplit system with heat recovery, all equipment sizes	
	Water cooled	Multisplit system, all equipment sizes	CEE Teir 1 \$125/ Ton
		Multisplit system with heat recovery, all equipment sizes	
Heat Pump Loop	Ground source, closed loop	All equipment sizes	\$125/ Ton
	Groundwater source, open loop		

### Notes for HVAC equipment incentives:

- Equipment that meets or exceeds the efficiency requirements listed for the size category in the above table may qualify for the listed incentive. Equipment must meet all listed efficiency requirements to qualify for the listed incentives.
- PTHPs can replace electric resistive heating, which must be removed.
- Incentives for heat pumps are available per ton of cooling capacity ONLY. No incentives are paid per ton of heating capacity. Heat pumps must meet both the cooling mode and heating mode efficiency requirements to qualify for per ton cooling efficiency incentives.
- Equipment size categories are specified in terms of net cooling capacity at AHRI standard conditions as determined by AHRI Standard 210/240 for units < 65,000 Btu/hr, AHRI Standard 340/360 for units ≥ 65,000 Btu/hr, AHRI Standard 310/380 for PTAC and PTHP units, and AHRI Standard 1230 for VRF systems.
- Ground- and water-source heat pumps must meet or exceed listed efficiency requirements when rated in accordance with ISO-13256-1 to qualify for the listed incentive.
- Efficiency requirements align with the unitary air conditioning and heat pump specification maintained by the Consortium for Energy Efficiency for equipment with heating sections other than electric resistance. CEE minimum efficiency requirements are listed at Wattsmart.com.
- Unitary commercial heat pumps ≥ 240,000 Btu/hr are eligible for custom incentive offerings based on efficiency criteria.

AHRI = Air-conditioning, Heating, and Refrigeration Institute

CEE = Consortium for Energy Efficiency

COP = Coefficient of Performance

EER = Energy Efficiency Ratio

HSPF = Heating Seasonal Performance Factor

HVAC = Heating, Ventilation and Air Conditioning

IEER = Integrated Energy Efficiency Ratio

PTAC = Packaged Terminal Air Conditioner

PTHP = Packaged Terminal Heat Pump

SEER = Seasonal Energy Efficiency Ratio

VRF = Variable Refrigerant Flow