

INCENTIVES FOR MOTORS

EQUIPMENT TYPE	SIZE CATEGORY	SUB-CATEGORY	MINIMUM EFFICIENCY REQUIREMENT	INCENTIVE
Electronically Commutated Motor (ECM) – Retrofit only	≤1 horsepower	Refrigeration application	—	\$3/watt
		HVAC application	—	\$200/horsepower
	> 1 hp and ≤ 10 hp	HVAC application	—	\$200/horsepower
Variable-Frequency Drives (HVAC fans and pumps)	≤100 horsepower	HVAC fans and pumps	See note 2	\$200/horsepower

Notes for other motor incentives:

- Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
- Throttling or bypass devices, such as inlet vanes, bypass dampers, three-way valves, or throttling valves must be removed or permanently disabled to qualify for HVAC fan or pump VFD incentives. VFDs required by or used to comply with the applicable version of the energy code are not eligible for incentives. Savings will only be realized for installations where a variable load is present.
- The maximum allowable incentive rates for energy-saving measures are posted in the most current [Schedule 140 tariff](#) as approved by the Utah Public Service Commission.

ECM = Electronically Commutated Motor

HVAC = Heating, Ventilation and Air Conditioning

NEMA = National Electrical Manufacturers Association

VFD = Variable Frequency Drive