

INCENTIVES FOR EVAPORATIVE COOLING

EQUIPMENT TYPE	SIZE CATEGORY	SUB-CATEGORY	MINIMUM EFFICIENCY REQUIREMENT	CUSTOMER INCENTIVE
Evaporative Cooling	All sizes	Direct or indirect	--	\$0.06/CFM
Indirect-Direct Evaporative Cooling (IDEC)	All sizes	--	Applicable system components must exceed minimum efficiencies required by the applicable version of the International Energy Conservation Code (IECC 2009)	See note 2
Evaporative Pre-cooler (Retrofit only)	--	For single air-cooled packaged rooftop or matched split-system condensers only	Minimum performance efficiency of 75%. Must have enthalpy controls to control pre-cooler operation. Water supply must have chemical or mechanical water treatment.	\$75/ton of attached cooling capacity (See note 3)

Notes for evaporative cooling incentives:

1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
2. Incentives paid at \$0.15/kWh annual energy savings + \$50/kW average monthly demand savings. IDEC energy and demand savings subject to approval by Rocky Mountain Power.
3. Incentives for evaporative pre-coolers are capped at 70 percent of energy efficiency project costs and incentives will not be available to reduce the energy efficiency project simple payback below one year. Energy efficiency project costs are subject to approval by Rocky Mountain Power.

CFM = Cubic Feet per Minute
 HVAC = Heating, Ventilation and Air Conditioning
 IDEC = Indirect-Direct Evaporative Cooling
 IECC = International Energy Conservation Code