

Inter-Set Device Policy—Idaho

Metering Policy No. 403

Authoring Department: Engineering Standards and Technical Services
 File Number-Name: 403-Inter-Set Device Policy-Idaho.docx
 Revision Number: 0
 Revision Date: 6/30/2016

Document Security Category			
	Confidential	x	External
	Restricted		BES Cyber System Information (BCSI)
x	Internal		

Revision Log		
0	6/30/2016	Initial publication.

Inter-Set Device Policy—Idaho

Metering Policy No. 403

Inter-set devices are defined as devices that are installed between the customer's meter socket and the company's meter.

Rocky Mountain Power does not allow the installation of inter-set devices in Idaho.